

GENERAL NOTES

- ALL PIPES, VALVES AND FITTINGS SHALL BE IN ACCORDANCE WITH THE WATER CORPORATION WATER SUPPLY RETICULATION MANUAL
- THE DIFFERENCE IN LEVEL BETWEEN THE CROWN OF THE PIPE AND ADJACENT FINISHED ROAD GUTTER SHALL NOT BE LESS THAN 600mm AND SHALL NOT EXCEED 700mm
- UNLESS OTHERWISE DIRECTED BY THE SUPERINTENDENT, THE DIFFERENCE IN LEVEL BETWEEN THE CROWN OF THE PIPE AND THE FINISHED VERGE LEVEL SHALL BE NOT LESS THAN 600mm AND SHALL NOT EXCEED 800mm
- WHERE PIPES CROSS OR ADJOIN OTHER EXISTING OR PROPOSED SERVICES, THE WATER MAIN SHALL HAVE A CLEARANCE OF 100mm
- UNLESS OTHERWISE SHOWN ON THIS DRAWING OR VARIED BY THE SUPERINTENDENT, ALL PIPES AND FITTINGS SHALL BE LAID ON AN ALIGNMENT OF 2.1m FROM THE CENTRE OF THE PIPE TO THE ROAD RESERVE BOUNDARY
- TEMPORARY DEAD ENDS, INSTALLED IN ACCORDANCE WITH THE SPECIFICATION, SHALL BE PROVIDED ON ALL MAINS AT CONNECTION POINTS TO EXISTING MAINS AND WHERE SPECIFIED
- ALL DIMENSIONS ARE IN METRES UNLESS OTHERWISE SHOWN
- UNLESS DIMENSIONED OTHERWISE, PE MAINS SHALL EXTEND AT LEAST 6.0m PAST THE LAST LOT SERVED
- ALL VALVES AND HYDRANTS SHALL BE PLACED OPPOSITE BOUNDARY PEGS OR IN THE CENTRE OF LOT FRONTAGES AS SHOWN
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE STANDARD DETAILS AND THE SPECIFICATION
- EXISTING POWER POLES ARE TO BE SUPPORTED DURING LAYING OF THE WATER MAIN, BY WESTERN POWER, AT CONTRACTORS EXPENSE
- ALL LOT CONNECTIONS AT FRONT
- PIPES TO BE DEFLECTED WHERE BEND TYPE NOT SPECIFIED

CONTRACTORS RESPONSIBILITY

IT IS THE CONTRACTORS RESPONSIBILITY TO ENSURE THE INDICATED POSITIONS FOR PRELAI SERVICES DO NOT CLASH WITH DRAINAGE OR OTHER FACILITIES. PLEASE CONTACT THE SITE SUPERINTENDANT IF AMENDMENTS TO THE PRELAI SERVICE LOCATIONS ARE REQUIRED

SERVICES

L OR R INDICATES THE SIDE OF THE LOT AS VIEWED FROM THE ROAD
 FR OR FL INDICATES LEFT OR RIGHT FULLY PRELAI SERVICE
 D INDICATES A DEFERRED SERVICE
 L80 OR R80 INDICATES LEFT OR RIGHT PVC DUCT.

FULLY PRELAI SHORT SINGLE SERVICES:	3
FULLY PRELAI SHORT DUAL SERVICES:	15
FULLY PRELAI LONG SINGLE SERVICES:	1
FULLY PRELAI LONG DUAL SERVICES:	3
DEFERRED SERVICES:	9
TOTAL NUMBER OF LOTS SERVED-	49

EXTENSION

LAY 549.2 METRES OF 100P-12
 242.4 METRES OF 200P-12

CONNECTION NOTES

ALL CONNECTIONS TO EXISTING MAINS BY WATER CORPORATION AT CONTRACTOR'S EXPENSE

STANDARD DRAWINGS

AS LISTED IN CURRENT WATER CORPORATION WATER SUPPLY RETICULATION MANUAL

LEGEND

- 63PE --- EXISTING WATER MAIN, PIPE SIZE AND TYPE
- 63PE --- NEW WATER MAIN, PIPE SIZE AND TYPE
- 63PE - - - FUTURE WATER MAIN, PIPE SIZE AND TYPE
- ↓ CHANGE OF PIPE SIZE, MATERIAL OR ALIGNMENT
- EXISTING HYDRANT
- NEW HYDRANT
- × EXISTING VALVE
- × NEW VALVE
- FP FLUSHING POINT
- L80 80mm UPVC DUCT
- D DEFERRED SERVICES
- FL FR SERVICE LOCATION
- - - LOCATION OF LONG SERVICE
- ★ LOTS SERVED BUT NOT RELEASED IN STAGE

250x200 TEE CONNECTION BY WATER CORPORATION AT CONTRACTORS EXPENSE

100 STRAIGHT CONNECTION BY WATER CORPORATION AT CONTRACTORS EXPENSE

CITY OF COCKBURN WAPC No 126771
 SUB FILE JT1 2004 10586 V01
 M/E FILE JT1 2006 13759 V01
PLAN No IS92-103-1A

THIS PLAN IS ACCEPTED AS COMPLYING WITH OVERALL WATER SUPPLY PLANNING. COMPLIANCE WITH WATER MANUALS REMAINS THE RESPONSIBILITY OF THE CONSULTING ENGINEER.
 FOR MANAGER DEVELOPMENT SERVICES BRANCH

EXISTING SERVICES - INFORMATION ON THESE DRAWINGS PURPORTING TO RELATE TO EXISTING SERVICES IS INDICATIVE ONLY AND MAY NOT BE COMPLETE REFER TO SPECIFICATION AND CLAUSE 12 OF AS4000



REV	REVISION	DATE	APPROVED
1	PRECAL AMENDED P.O.S. & LOTS 698-400		
0	PRECAL, WATER ROAD TWO AMENDED, WATER CORPORATION NOTES ADDED	17/01/07	L.M.
A	ISSUED FOR APPROVAL	25/10/06	P.J.G.

CLIENT
MILUC INVESTMENTS PTY LTD

DPM
DENNIS, PRICE & MILLER (WA) PTY LTD
 CONSULTING CIVIL ENGINEERS
 38 Richardson Street West Perth WA 6005
 Telephone: (08) 9481 4255 Facsimile: (08) 9481 3900
 Email: dpmwa@dpmwa.com.au
 ACN 006 843 705

DRAWN	L. Fisher
DESIGNED	L. Fisher
CHECKED	B. Griffiths
APPROVED	L. Murtagh
DATE	17/01/07

TITLE
**LOT 446 LYON ROAD
 AUBIN GROVE
 WATER RETICULATION PLAN**

ORIGINAL SHEET SIZE	A1
SCALE	1:500
LEVEL DATUM	AHD
SHEET	1 OF 1
DRAWING No	7359-06
REV	1

WAPC No 126771